

Axial Flow Fans **DuctMaster Circular Bifurcated**




Fig. 1. General view of unit.

Introduction

The NuAire DuctMaster bifurcated range of Axial Flow Fans are produced in seven case sizes from 315mm dia. to 630mm dia. with duties from 0.25m³/s to 5.25m³/s.

The units are available in standard or high temperature types.

Impellers have been selected at 5 degree blade intervals matched to various motor speeds to provide a range of units that will suit your specific individual performance requirements.

Blades are adjustable and can be reset to suit final system resistances if necessary. However, we strongly recommend that you contact NuAire before any blade angle changes are undertaken.

NuAire will not accept responsibility for damaged units when unauthorised personnel have altered blade angles. Units are available for both single or three phase operation. Some units are suitable for inverter speed control, contact NuAire for full details.

NuAire DuctMaster Bifurcated fans have been tested to BS 848 in our BSI approved laboratories. This ensures that all technical data is accurate and that all units can be specified with confidence.

Installation and Maintenance

NUAIRE

NuAire Limited, Western Industrial Estate, Caerphilly, Mid Glamorgan, CF83 1XH. United Kingdom. Telephone: 02920 885911 Facsimile: 02920 887033 Email: info@nuaire.co.uk

Leaflet 670679

AUGUST 1999

Page

Contents

Introduction / General Description	1
Dimensions	2
Installation	3
Silencer Information	5
Ancillaries Information	7
Fixing Details	8
Wiring Details	10
Spares & Service	14

General Description

The DuctMaster Bifurcated range of Axial Flow Fans has been designed specifically for ease of installation into new or existing ductwork systems. Each fan is supplied complete with two matching flanges, self sealing clamping collars and four mounting feet with fixings. The fan casing incorporates two integral, opposed, mounting pads. Each pad has multiple fixing holes for the feet allowing installation in any mounting plane.

Anti-vibration Mounting kits are available on request.

The case flanges mate with ductwork etc using single bolt quickfit clamping collars.

A full range of ancillaries is available including matching Silencers, Flexible Connectors, Wall Support Brackets and Controls.

Many fans are fully compatible with Microsave and conventional controls (For controls see Data Sheet Leaflet No 670673 for full details).

Ductmaster models are also available polyester powder painted for external use.


WARNING!


- **1.** Do not reverse impeller direction for operation as the performance of the unit is drastically reduced (see start up procedure).
- **2.** Do not alter the blade angle of the impeller without the permission of NuAire.

THE ABOVE MAY INVALIDATE YOUR WARRANTY

Fan Dimensions

D






Matching

Dimensions ((mm)							Uni Weigh	-
Unit Code	Α	В	С	D	Ε	F	G	2 Pole	4Pole
DCB 315	310	360	433	369	298	265	168	22	22
DCB 350	345	395	433	427	339	265	168	25	25
DCB 400	395	445	500	442	384	218	168	31	28
DCB 450	445	475	500	514	424	319	168	38	32
DCB 500	493	545	605	555	488	326	168	49	43
DCB 560 (4 Pole)	553	605	606	633	565	278	168	-	43
DCB 560 (2 Pole)	553	605	606	633	527	418	168	55	-
DCB 630 (4 Pole)	622	674	651	729	615	428	168	-	65
DCB 630 (2 Pole)	622	674	651	751	619	468	168	84	-

Mounting Foot

_

Four mounting feet are supplied with each unit or silencer, see main fixing drawings. M8 fixing screws are included.



Handling

The DuctMaster fan impeller is carefully balanced prior to despatch. Care must be taken on site when handling the unit not to damage or distort the blades or alter the motor position. Do not pass lifting slings etc through the impeller. Always use the mounting pads (top or bottom) for sling attachments.

The fan is supplied with installation accessories i.e. two matching flanges, two clamping collars and four mounting feet attached. These items are fitted before delivery to ensure parts are not lost on site. If the optional flexible connectors are specified these will be fitted for delivery to the customer. However care must be taken when handling the unit assembly as the flexibles can be distorted or damaged.

Installation

Application

Unit

For external use it is good practice that the unit is installed so that the motor tunnel is horizontal. Also the unit will be painted RAL9014 (grey) which is suitable for maximum temperatures of 230° C.

For internal use it is good practice that the unit be installed so that the motor tunnel is vertical for a horizontal airflow.

Prior to installation the impeller should be rotated by hand to check for smooth rotation and that no transit damage has occurred.

Horizontal on floor etc.

Before commencing work it will be necessary to remove the clamping collars and loose flanges. Simply unscrew the clamp nut using a suitable spanner.

Note: during installation, ensure that the flanges are mated together correctly before tightening the clamps. The position of the shakeproof washers on the foot mountings is important as these washers are fitted to restrain any longitudinal movement of the feet. See fixing details on page 6 noting that you have a choice of two holes when fitting the feet for floor mounting.

If the optional resilient mountings have been chosen these should be attached to the unit feet at this stage. See Resilient Mounting assembly (floor mtg) drawing on page 6. Note that the large steel safety washers in the mounting kit are not required for floor mounting and can be discarded. Details of resilient mounting kit selection is shown in the table on the same page.

If the optional wall support brackets are to be used they

could be attached to the feet of the fan in order to determine the ducting centreline relative to the mounting plane. (Foot fixing centres are shown on fixing details drawing which should allow the brackets to be pre fitted to the wall ready to accept the fan assembly).

Consider the position of the fans electrical terminal box when choosing an installation position.

Assuming that the position for mounting has been chosen. and any wall brackets (if used) are already correctly located, stand or support the unit in place and check the unit is aligned with the ductwork in both horizontal and vertical planes. A degree of adjustment is provided on the feet but it may be necessary to pack up the height under the mounting feet. See fixing details on page 9.

Mark on the floor / structure the fixing positions for the feet or resilient mountings and if necessary drill suitable holes to accept bolt or screw fixings (screws not supplied).

If matching silencers are to be installed, these should be fitted to the fan with any other accessories such as flexible connectors etc. before installation and the complete assembly mounted in position using the same procedure. The matching flanges if required on the installation are fixed to the ductwork ends with rivets etc. Ensure the clamping collars have been placed onto the ducting before drawing the flanges together. Note: make sure the flange faces are properly mated before fitting and tightening the clamping collars.

Suspended horizontally or vertically

The only difference for suspension is in the positioning of the mounting feet which are now fixed to the sides of the mounting pads by the smaller single hole leg of the feet. See fixing details on page 9.

If Resilient Mountings are to be included note that the rubber mountings **must** remain in compression - this involves fixing the rubber mounting upside down inside the foot. The large metal safety washers **must** be fitted under the studding nuts on each mounting. See Resilient Mounting assembly (suspended) drawing on page 6.

General.

Motors are totally enclosed and protected to IP55 (Dust and low pressure water jets). Motors may incorporate drain holes to allow any condensation to escape from the motor casing. It is essential therefore that these drain holes are positioned at the lowest point of the fan motor when the unit is horizontally mounted.

All bearings are pre-packed with grease and sealed for life.

Connection details

Check that the voltage on the fan rating label is suitable for your supply. Full load / starting currents are also indicated.

The fan unit incorporates a terminal box on the motor exterior. Units for external use require weatherproof conduit and glands.

Motors up to and including 3kW are designed for Direct On Line starting. Motors with outputs of 4kW and above are suitable for Direct On Line or Star/Delta starting.

Flameproof motors are generally supplied for wiring and connection, direct to the motor terminals, on site by the installer (special wiring instructions must be provided by NuAire). Connections and fittings used must be in accordance with current BASEEFA approved standards and requirements.

Motor overload protection should be set to the full load current on the fan rating label. Supply fuses should be H.R.C. type.

Start up procedure

When starting ensure that the impeller rotation follows the label arrow indicator on the casing. Should the direction be incorrect on three phase units, reverse any two of the supply leads. See wiring diagrams pages 10. (Do not reverse the impeller direction permanently).

Equipment should be run for approximately 30 minutes to ensure correct operation. If any fault occurs, the equipment should be switched off. Do not re-start until the fault has been rectified.

Accessory Installation

Flexible Connections - Care must be taken when installing flexible connections to ensure that duct misalignment is not corrected by the flexible connection. Both duct misalignment and slack connections cause unnecessary pressure losses in the system.

Anti-Vibration Mountings - Anti-vibration mounts cannot be fitted to a fan unless there are flexible connectors between the fan or fan silencer combination casing and the ducting. On combination fan/silencer installations only four foot mountings are used, see fixing details on page 9.

Suspension mounts in particular should be adjusted on the drop rods to carry an equal proportion of the total fan weight when installed, as unevenly adjusted mountings could carry a load greater than the design condition.

Anti-Backdraught Dampers - Anti-Backdraught Damper should be checked for transit damage prior to installation. Damper blades should be open and closed to ensure smooth operation.

Maintenance

NuAire recommends all products maintained in accordance with the HVCA "Standard Maintenance Specification for Mechanical Services in Buildings" -Volume II Ventilating and Air Conditioning.

For guidance only

Due to the different periods of operation from the time of installation and conditions of use, no rigid inspection and maintenance periods can be recommended. We suggest,

therefore that the inspection and if necessary cleaning / bearing check should be carried out at regular intervals of a maximum of six months.

For a routine inspection, check the tightness of all nuts, keys, grubscrews and endbolts etc. Remove any build up of dirt or dust with a brush.

Silencers В С Clamping Collar A DCS315S to DCS630S. Short Un-podded. DCS315L to DCS630L. Long Un-podded. D DCSP315S to DCSP630S. Short Podded. DCSP315L to DCSP630L. Long Podded. F Е Note: Podded silencer illustrated

Dimensions Unit Code	(mm) A	В	C Short	C Long	D	E	F Short	F Long	Weight Short Podded	(kg) Short No Pod	Long Podded	Long No Pod
DCS 315	310	410	374	684	450	355	230	230	11.0	7.0	17.0	13.0
DCS 350	345	445	409	754	510	355	230	230	14.0	10.0	24.0	17.0
DCS 400	395	495	459	854	540	405	230	230	16.0	12.0	29.0	22.0
DCS 450	445	545	509	954	600	405	230	230	23.0	19.0	37.0	30.0
DCS 500	493	643	557	1050	666	502	230	230	29.0	25.0	45.0	37.0
DCS 560	553	703	617	1170	726	565	230	230	32.0	29.0	47.0	40.0
DCS 630	622	772	686	1308	795	630	230	230	36.0	34.0	58.0	52.0

Construction

NuAire DuctMaster attenuators for Bifurcated units are manufactured with a rigidly constructed, cylindrical galvanised steel casing. The casing is lined internally with sound absorbent material which has excellent acoustic properties, is non-hygroscopic and also incombustible. The material is retained by a perforated aluminium liner.

Each silencer has two opposed mounting pads with multiple mounting feet fixing points.

Flanges are quickfit type to match the DuctMaster Bifurcated axial fans.

Four mounting feet, feet fixings and a clamping collar are supplied with each silencer.

When a pod is fitted it is constructed of perforated aluminium with an infill of the acoustic material.

Silencer Types

Two types of cylindrical silencer are available: **Unpodded : Ref = DCS Podded : Ref = DCSP** (The introduction of the pod considerably improves the attenuation but increases resistance to airflow).

Two standard lengths of silencers are available: **Short : Ref = S Long : Ref = L**

Examples:


a) **DCSP 315 S** is a short silencer with a pod.

b) DCS 315 L is a long silencer without a pod.

Four mounting feet c/w fixings (supplied with unit). E È Mounting pad upon unit. Shakeproof washers ш Nuts used for height adjustment. Thread insert. DAV1 = 30 DAV1 = M8DAV2-6 = 40DAV2-6 = M10/M12Resilient mounting DAV1 = 50kit c/w fixings DAV2 - 6 = 75 (four supplied).

Resilient Mounting 'Floor' fixing

Resilient Mounting 'Suspended' fixing




Resilient Mounts

The above anti vibration mountings are available for the DuctMaster Bifurcated range of axial flow fans. See selection table opposite.

Kits are supplied for unit or unit silencer combinations and comprise the requisite number of resilient mounts for 'floor' or 'suspension' use (see details above).


Unit Code					1)						
Cour	Unit Motor Poles	Unit Only	One	Plus Short ncer	Two	Plus Short 1cers	One	Plus long ncer	Unit Plus Two long Silencers		
	(kw)		Pod	No Pod	Pod	No Pod	Pod	No Pod	Pod	No Pod	
DCB315	2 & 4	DAV1	DAV2	DAV2	DAV2	DAV2	DAV2	DAV2	DAV5	DAV2	
DCB350	2 & 4	DAV2	DAV2	DAV2	DAV2	DAV2	DAV2	DAV2	DAV5	DAV2	
	2	DAV2	DAV2	DAV2	DAV2	DAV2	DAV2	DAV2	DAV5	DAV5	
DCB400	4	DAV2	DAV2	DAV2	DAV2	DAV2	DAV2	DAV2	DAV5	DAV5	
2	c (10° -20°)	DAV2	DAV2	DAV2	DAV5	DAV5	DAV5	DAV2	DAV5	DAV5	
DCB450 2	(21° -25°)	DAV2	DAV2	DAV2	DAV5	DAV5	DAV5	DAV2	DAV5	DAV5	
	4	DAV2	DAV2	DAV2	DAV5	DAV2	DAV2	DAV2	DAV5	DAV5	
-	2	DAV2	DAV5	DAV5	DAV5	DAV5	DAV5	DAV5	DAV5	DAV5	
DCB500	4	DAV2	DAV5	DAV2	DAV5	DAV5	DAV5	DAV5	DAV5	DAV5	
	2	DAV2	DAV5	DAV5	DAV5	DAV5	DAV5	DAV5	DAV5	DAV5	
DCB560	4	DAV2	DAV5	DAV2	DAV5	DAV5	DAV5	DAV5	DAV5	DAV5	
	2 (10°)	DAV5	DAV5	DAV5	DAV5	DAV5	DAV5	DAV5	DAV3	DAV3	
DCB630	2 (12°-15°)	DAV5	DAV5	DAV5	DAV3	DAV3	DAV3	DAV3	DAV3	DAV3	
	4	DAV5	DAV5	DAV5	DAV5	DAV5	DAV5	DAV5	DAV3	DAV5	

Mounting Foot details



Mounting Foot Notes

Four mounting feet are supplied with each unit or silencer, see main dimension drawings. M8 fixing screws are included. Note: See fixing details, page 9.



630

715

60

4.6 5.0

Fixing Details Unit only Supported horizontally from floor. Side view End view В Suspended horizontally from above. A1 В Side view End view Suspended vertically from above. B1 F


View on **'Z'**


Dimensions of fixing centres																
Unit Code	Dim	ension	s (mm)	betwee	en foot fiz	0	e centr	es								Drop** rods and
Coue					short silencer	long silencer			short silencer	long silencer				short silencer	long silencer	bolt sizes
	A	A1	В	B1	C	C	D	D1	E	E	F	G	Н	J	J	mounts
DCB3152&4	298	348	265	188	656	811	355	405	1041	1351	469	483	243	230	230	M8/M10
DCB350 2 & 4	339	389	266	229	675	847	355	405	1077	1421	527	518	243	230	230	M8/M10
DCB400 2 & 4	384	434	218	274	708	905	405	455	1194	1588	542	568	293	230	230	M10
DCB450 2 & 4	424	474	319	314	784	1003	405	455	1244	1682	614	618	293	230	230	M10
DCB500 2 & 4	484	534	294	374	830	1076	502	552	1362	1854	653	716	393	230	230	M10
DCB560 4	562	612	256	452	841	1117	565	615	1422	1974	732	776	453	230	230	M10
DCB560 2	530	580	256	420	841	1117	565	615	1422	1974	732	776	453	230	230	M10
DCB630 4	616	666	391	506	943	1254	630	680	1490	2112	825	845	523	230	230	M10
DCB630 2	596	646	391	486	943	1254	630	680	1490	2112	825	845	523	230	230	M10
DCB630 2	596	646	391	486	943	1254	630	680	1490	2112	825	845	523	230	230	M10


View on '**Y**'

'Z'

'Y'







Silencer

NOTE: 4 Drop rods only required on units up to 630. Additional rod positions are shown shaded.

INSTALLATION NOTES:


For internal use it is good practice that the unit be installed so that the motor 'tunnel' is vertical to provide a natural vertical movement of air cooling the motor. In this attitude, the mounting feet would be fixed to the mounting pad 'faces'.

For external use it is good practice that the unit be installed with the motor 'tunnel' horizontal. In this attitude, the mounting feet be would fixed to the mounting pad sides.

Electrical Information


Wiring Details

1 PHASE SINGLE SPEED




230V 1 phase 50Hz supply


3 PHASE FOR D.O.L. STARTING



400V 3 phase 50Hz supply

3 Phase for Star / Delta starting (4kW and above)





NOTE: LOW SPEED - Supply: 1U 1V 1W

HIGH SPEED - Supply: 2U 2V 2W LINK 1U 1V 1W

400V 3 phase 50Hz supply

2 SPEED TAP/ PAM WOUND MOTOR (D.O.L. starting both speeds)

Speed Controls, Starters & Isolators (see easy selection tables) Dimensions(mm)												
Unit type or code		Trar	nsform	ner sp	eed o	contro	ols			Isolators	Starters	MicroSave controls
	SP CON 4	SP CON 5	SP CON 6	SP CON 7	3SP CON 1	3SP CON 1A	3SP CON 2	3SP CON 4	3SP CON 7	DMISOL (all units)	STAR (all units)	Interface control panel for starters & Speed controls (all units).
Depth	75	105	105	110	110	110	110	135	135	90	47	37
Height	140	185	185	255	253	253	253	309	309	135	148	87
Width	315	315	315	190	188	188	188	262	262	95	88	147

MICROSAVE Controls

DuctMaster Bifurcated is compatible with Microsave Starters and Speed Controls: SEE INSIDE REAR COVER For further details refer to:

Microsave/Masterclass Selection Guide Leaflet No. 670588 and Technical Data Sheet Nos. 670578 'Speed Controls' 670579 'Starters'.

For Microsave wiring information please refer to : Microsave Starter controls Leaflet No. 670579 Microsave Speed controls Leaflet No. 670578



CE DECLARATION OF CONFORMITY

NuAire Limited, Western Industrial Estate, Caerphilly, Mid Glamorgan, CF83 1XH. United Kingdom. Telephone: 01222 885911 Fax: 01222 887033 Email: info @ nuaire.co.uk

Leaflet

OCTOBER 1998

We declare that the machine named below conforms to the requirements of EC Council Directives relating to Electromagnetic Compatibility and Safety of Electrical Equipment.

Designation of machinery :-

Machinery Types :-

Relevant EC Council Directives :-

Applied Harmonised Standards :-

Basis of Self Attestation :-

1)

2)

DUCTMASTE BIFURCATED FAN

DCB

89/336/EEC, 92/31/EEC (EMC) 73/23/EEC, 93/68/EEC (Low Voltage Directive)

E50081-1, EN50082-1, EN60204-1 EN60335-2-80

Quality Assurance to BS EN ISO 9001 BSI Registered Firm Certificate No. FM 149

Signature of manufacture representatives :-

	Name:	Position:	Date:
Contras	C. Biggs	Technical Director	2. 4. 98
Michael gFussel	M. Fussell	Manufacturing Director	2. 4. 98



DECLARATION OF INCORPORATION & INFORMATION FOR SAFE INSTALLATION, OPERATION & MAINTENANCE

NuAire Limited, Western Industrial Estate, Caerphilly, Mid Glamorgan, CF8 1XH. United Kingdom. Telephone: 01222 885911 Fax: 01222 887033 Email: info @ nuaire. co. uk

0CTOBER 1998

We declare that the machinery named below is intended to be assembled with other components to constitute a system of machinery.

The machinery shall not be put into service until the system has been declared to be in conformity with the provisions of the EC Council Machinery Directive.

Designation of machinery :-	DUCTMASTER BIFURCATED FAN
Machinery Types :-	DCB
Relevant EC Council Directives :-	98/37/EC (Machinery Directive) 93/44/EEC (Amendment to the Machinery Directive)
Applied Harmonised Standards :-	EN292-1, EN292-2, EN294, EN29001
Applied National Standards :-	BS848 Parts One, Two and Five

Signature of manufacture representatives :-

	Name:	Position:	Date:
1)	C. Biggs	Technical Director	3.1.98
2) Michael Hussel	M. Fussell	Manufacturing Director	3.1.98

INFORMATION FOR SAFE INSTALLATION, OPERATION AND MAINTENANCE OF NUAIRE VENTILATION EQUIPMENT

To comply with EC Council Directives 89/392/EEC Machinery Directive & 93/44/EEC Amendment to the Machinery Directive.

To be read in conjunction with the relevant Product Documentation (see 2.1)

1.0 GENERAL

1.1 The equipment referred to in this **Declaration of Incorporation** is supplied by NuAire to be assembled into a ventilation system which may or may not include additional components.

The entire system must be considered for safety purposes and it is the responsibility of the installer to ensure that all of the equipment is installed in compliance with the manufacturers recommendations and with due regard to current legislation and codes of practice.

2.0 INFORMATION SUPPLIED WITH THE EQUIPMENT

- 2.1 Each item of equipment is supplied with a set of documentation which provides the information required for the safe installation and maintenance of the equipment. This may be in the form of a Data sheet and/or Installation and Maintenance instruction.
- 2.2 Each unit has a rating plate attached to its outer casing. The rating plate provides essential data relating to the equipment such as serial number, unit code and electrical data. Any further data that may be required will be found in the documentation. If any item is unclear or more information is required, please contact NuAire.
- 2.3 Where warning labels or notices are attached to the unit the instructions given must be adhered to.

3.0 TRANSPORTATION, HANDLING AND STORAGE

- 3.1 Care must be taken at all times to prevent damage to the equipment. Note in particular that shock to the unit may result in the balance of the impeller being affected.
- 3.2 When handling the equipment, care should be taken with corners and edges and that the weight distribution within the unit is considered. Lifting gear such as slings or ropes must be arranged so as not to bear on the casing.
- 3.3 Equipment stored on site prior to installation should be protected from the weather and steps taken to prevent ingress of contaminants.

4.0 OPERATIONAL LIMITS

- 4.1 It is important that the specified operational limits for the equipment are adhered to *e.g. operational air temperature, air borne contaminants and unit orientation.*
- 4.2 Where installation accessories are supplied with the specified equipment eg. wall mounting brackets. They are to be used to support the equipment only. Other system components must have separate provision for support.
- 4.3 Flanges and connection spigots are provided for the purpose of joining to ductwork systems. They must not be used to support the ductwork.

5.0 INSTALLATION REQUIREMENTS

In addition to the particular requirements given for the individual product, the following general requirements should be noted.

- 5.1 Where access to any part of equipment which **moves**, or can become **electrically live** are not prevented by the equipment panels or by fixed installation detail (eg ducting), then guarding to the appropriate standard must be fitted.
- 5.2 The electrical installation of the equipment must comply with the requirements of the relevant local electrical safety regulations.

6.0 COMMISSIONING REQUIREMENTS

6.1 General pre-commissioning checks relevant to safe operation consist of the following -Ensure that no foreign bodies are present within the fan or casing

Check electrical safety. *e.g. Insulation and earthing.*

Check electrical safety. *e.g.* If

Check guarding of system. Check operation of Isolators/Controls.

Check fastenings for security.

6.2 Other commissioning requirements are given in the relevant product documentation.

7.0 OPERATIONAL REQUIREMENTS

- 7.1 Equipment access panels must be in place at all times during operation of the unit, and must be secured with the original fastenings.
- 7.2 If failure of the equipment occurs or is suspected then it should be taken out of service until a competent person can effect repair or examination. (Note that certain ranges of equipment are designed to detect and compensate for fan failure).

8.0 MAINTENANCE REQUIREMENTS

- 8.1 Specific maintenance requirements are given in the relevant product documentation.
- 8.2 It is important that the correct tools are used for the various tasks required.
- 8.3 If the access panels are to be removed for any reason the electrical supply to the unit must be isolated.
- 8.4 A minium period of two minutes should be allowed after electrical disconnection before access panels are removed. This will allow the impeller to come to rest.

NB: *Care should still be taken however since airflow generated at some other point in the system can cause the impeller to "windmill" even when power is not present.*

8.5 Care should be taken when removing and storing access panels in windy conditions.

3 YEAR WARRANTY

The three year warranty starts from the date of delivery and includes parts and labour for the first year.

The labour element is subject to full, free and safe access to the equipment as recommended by the CDM regulations.

The remaining two years covers replacement parts only.

NOTE:

Installation & Maintenance of the equipment must be as directed in the instructions provided with the unit.

Spares

In view of the fact that the product incorporates sealed for life bearings and utilises no consumables we would not recommend a stock holding of spares. In the unlikely event that a failure should occur contact our service department and quote the fan rating label details.

Controls Application Service (CAS)

A team of Engineers and technicians is available to provide pre and post order support.

We are on hand to provide help and advice from the most basic use of any NuAire equipment to the more complex applications, maximising on the versatility of our SMART and NetLink control products.

Telephone: 01222 858585

Facsimile: 01222 858586

Service

As a manufacturer NuAire provides you with factory trained Service Engineers.

Our Engineers are supported by a comprehensive range of spare parts 'off the shelf'.

If you are an industrial or commercial user, you may be interested in details of NuAire's regular maintenance Service Contracts. This is a worthwhile service that helps you get the most from our products.

Our Service Department will be happy to give you more information.

Please Telephone: 01222 858271

WARNING!

- **1.** DO NOT REVERSE IMPELLER DIRECTION FOR OPERATION AS THE PERFORMANCE OF THE UNIT IS DRASTICALLY REDUCED.
- **2.** Do not alter the blade angle of the impeller without the permission of NuAire.

THE ABOVE MAY INVALIDATE YOUR WARRANTY

Technical or commercial considerations may, from time to time, make it necessary to alter the design, performance and dimensions of equipment and the right is reserved to make such changes without prior notice.

NB

If you have any comments or queries on any of our products or services please write to the Marketing Services Manager at the main address above.



Western Industrial Estate, Caerphilly, Mid Glam CF8 1XH United Kingdom. Telephone: 02920 885911 Facsimile: 02920 887033

Leaflet No. 670679