## Product fiche according to Commission Regulation (EU) 1254/2014

•	Cuprier name		Nucino		
a h	Supplier name Model	Nuaire			
b c		Cold	MRXBOX95-WH1 Cold Average Warm		
	Specific energy consumption and SEC class $C_{\rm SEC}$ ( $\mu(\mu) + \mu_{\rm SEC}^2$ a)		Average		
	SEC (KWh/m <sup>2</sup> .a)	-86.6	-42.8	N/A	
	SEC Class		A+ A+ N/A		
d	RVU or NRVU / Unidirectional or bidirectional	RVU / Bi-directional			
e	Type of drive (multi-speed drive or variable speed drive)	Variable speed drive			
e f	Type of heat recovery system (recuperative, regenerative,	variable speed unive			
	none)	Recuperative			
g	Thermal efficiency of heat recovery		85%		
ь h	Maximum flow rate $(m^3/h)$		330		
i	Electric power input of the fan drive at maximum flow rate	330			
'	(W)	158			
i	Sound power level (LWA)	48			
j k	Reference flow rate $(m^3/s)$	0.064			
	Reference pressure difference (Pa)		50		
m	Specific power input (SPI) (W/(m <sup>3</sup> /h))		0.235		
	Control factor and control typology				
n	control factor and control typology	0.65 based o	0.65 based on boost by local light		
			switches		
0	Maximum internal and external leakage rates (%)	< 5% Internal, <5% External			
р	Mixing rate of non-ducted bidirectional ventilation units not				
	intended to be equipped with one duct connection on either	N/ / A			
~	supply or extract air side		N/A		
q	Position and description of visual filter warning for RVUs intended for use with filters, including text pointing out the				
	importance of regular filter changes for performance and	Refer to 18 M	Refer to I&M instructions supplied		
	energy efficiency of the unit	with the unit			
r	For unidirectional ventilation systems, instructions to install				
•	regulated supply/exhaust grilles in the façade for natural air				
	supply/extraction		N/A		
s	Internet address for pre-/dis-assembly instructions	www.nuair	www.nuaire.co.uk/disassembly		
		instructions			
t	For non-ducted units only: the airflow sensitivity to pressure				
	variations at + 20 Pa and – 20 Pa		N/A		
u	For non-ducted units only: the indoor/outdoor air tightness in				
	m <sup>3</sup> /h		N/A		
v	The annual electricity consumption (AEC) (in kWh				
	electricity/a)		1.24		
w	The annual heating saved (AHS) (in kWh primary energy/a)	Cold	Average	Warm	
		89.8	45.9	N/A	

060954